



## **K SERIES CHILLERS**

**KTR, KTC, KTD**

### **STANDARD MODELS**

### **INSTRUCTION MANUAL**

Issue 7.0



Applied Thermal Control Ltd.  
The Courtyard  
Whitwick Business Park  
Stenson Road  
Whitwick, Leicestershire  
LE67 4JP

Tel: +44 (0) 1530 839998

Fax: +44 (0) 1530 813786



<b>1.0 INTRODUCTION</b>	<b>3</b>
Safety	4
<b>1.1 Warranty registration</b>	<b>5</b>
<b>1.2 Unpacking</b>	<b>5</b>
<b>1.3 Site requirements</b>	<b>6</b>
<b>2.0 INSTALLATION</b>	<b>6</b>
Fluid line requirements	6
Voltage selection option	7
Chiller filling procedure	8
<b>3.0 OPERATION</b>	<b>9</b>
KTR models only	9
KTC models only	9
KTD models only	10
Adjusting the set point (KTD only)	10
CAL controller error messages (KTD only)	10
<b>4.0 MAINTENANCE REQUIREMENTS, OPERATOR</b>	<b>11</b>
<b>5.0 TECHNICIAN SECTION</b>	<b>12</b>
5.1 Fluid flow and pressure adjustment	12
5.2 Maintenance and service requirements	13
5.3 Troubleshooting	14
<b>6.0 WARRANTY TERMS AND CONDITIONS</b>	<b>15</b>
Registration	15
<b>6.1 Return of goods procedure</b>	<b>16</b>
<b>6.2 Specifications</b>	<b>17</b>
Environmental	17
KTR	17
KTC	17
KTD	18
<b>EC DECLARATION OF CONFORMITY</b>	<b>19</b>

---

## 1.0 Introduction

---

By selecting a K series chiller you have invested in many years experience in the design and manufacture of precision temperature control instrumentation.

ATC has built your K series chiller without compromise to meet the objectives of performance and reliability.

Please read this manual carefully to ensure you understand the operation of the machine and how to use the unit safely and efficiently.

If you have any questions regarding installation or repair of this unit please contact ATC at:


Applied Thermal Control Ltd.  
The Courtyard,  
Whitwick Business Park,  
Stenson Road,  
Whitwick,  
Leicestershire, LE67 4JP,  
UK

Tel: +44 (0) 1530 839998  
Fax: +44 (0) 1530 813786  
e-mail: [sales@app-therm.com](mailto:sales@app-therm.com)


Or contact an approved ATC distributor.


**Safety**

For your safety we draw your attention to the following **Warning** and **Caution** statements throughout this manual, identified by the symbols...





respectively. The safe operation of a KT series chiller remains the responsibility of the operator at all times.


 **Attention:** Failure to comply with a Caution will invalidate product warranty and absolve ATC from any liability, howsoever caused, and could result in permanent damage to equipment.

 **Caution:** Failure to comply with a 'Warning' may result in personal injury or death. ATC does not accept any liability for injury caused through use of this equipment.

---

 **Warning:** If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

 **Warning:** There are no user serviceable parts in this equipment.

 **Caution:** The high integrity refrigeration system contains no user-serviceable parts. Repair and service requires specialised knowledge and tools. Any unauthorised tampering with the refrigeration system automatically invalidates warranty.

## 1.1 Warranty registration

The warranty registration card must be completed and returned to ATC.


This does not affect your statutory rights.

## 1.2 Unpacking

Please check that both the packaging and the unit are undamaged. If there is any doubt, it is vital that you inform both ATC and the carrier before making a claim on the carrier. There are no hidden shipping bolts or other fixings. You should inspect the packaging for signs of transit damage before signing for the unit, and if possible unpack the unit before signing. Once you have signed for the goods, ATC cannot be held responsible for any transit damage subsequently found.



**Warning:** 30kg (66lb) – Two person lift required.



Remove the unit from its original packaging and ensure that there is no packaging left around the cooling ducts.

***Please retain all packaging in the unlikely event that the chiller needs to be returned to our local representatives.***

### 1.3 Site requirements

- **Hard, level surface.**
- **Clean, dust free environment.** Air-cooled chillers move large volumes of air, and large amounts of air-borne contamination will result in fouling of the condenser. This will reduce the capacity of the unit and in extreme cases cause a system shut-down.
- **Non-condensing ambient,** from +4°C to +40°C. Maximum cooling capacity is achieved at 22°C, and will de-rate by 2% per °C until capacity is lost at 30°C.
- **Electrical supply.** Two standard versions are available, 230V 50Hz 3A or 115V 60Hz, 6A. Other options are available on request.
- **Clearance** front and rear of the unit at least 250mm (10 inches).
- **Plumbing** to be clean and compatible with the fluid to be used. It is advisable that the minimum of right angle bends and compression fittings are used to reduce pressure losses in the pipework. See also section 2.0

## 2.0 Installation

Having ensured that your installation meets all of the site requirements identified in section 1.3, it is best practice that the fluid lines between your application and the chiller have the following characteristics.

### ***Fluid line requirements***

- *As short as possible.* Ideally between 1 and 2 metres (between 3 and 6 feet).
- *Large diameter.* Ideally at least 12mm (½ inch) internal diameter
- *Black tubing,* to inhibit growth of algae. Alternatively, use solid copper or welded ABS.
- *Free from right angle bends*
- *Clean.* If your installation is to existing pipe work, the system should be flushed clean prior to filling. Hexid fluids are the recommended coolant choice as they

provide excellent corrosion protection, freeze protection, algae inhibition and good heat transfer properties.

**i** **Caution:** Always use ATC recommended fluids in your K series chiller. Never use other anti-freeze mixtures, as they may corrode your application and will damage the K series pump seals.

All connections should be made using the fittings and clips provided. Where threaded or compression type fluid joints are to be made, always use a suitable jointing compound such as PTFE tape.

#### *Voltage selection option*

**i** **Caution:** If your KT chiller is rated for multi-tap and dual frequency operation, it is essential that the voltage selector switch on the KT chiller is set to match the voltage and frequency available at your site. The voltage selector switch cover plate can be found on the right side of the chiller cover, when viewed from the front. Access is via the four securing screws on the cover plate.

Having ensured that the system is correctly connected, with the inlets and outlets having the correct orientation relative to your application, all joints tight and leak free, and with the unit isolated from the electrical supply, prepare to fill the unit with Hexid fluid.

### *Chiller filling procedure*

1. Check valves in your application are open
2. Remove lid from the coolant reservoir
3. Fill with Hexid to within 40mm (1½ inches) of the tank rim.
4. Switch the unit on.
5. Wait while the fluid level drops in the tank.
6. Switch the unit off.
7. Repeat steps 3 to 5 until all of the air has been purged from the system.
8. Top up to a level 40mm (1½ inches) below the tank rim.
9. Check the inlet and outlet connections, and the inside of your application carefully for leaks. If no leaks are found, the system is ready to be run.



**Warning:** Always isolate the chiller from the electrical supply when filling the tank.

### *Component identification photograph, KT series* (model shown is KTR)





### 3.0 Operation


#### ***KTR models only***

Connect the mains cable and switch the unit on. The neon will illuminate, and the chiller runs automatically. KTR chillers have been configured to provide temperature stability to  $\pm 0.2^{\circ}\text{C}$ , and the actual temperature achieved will be in the range  $12^{\circ}\text{C}$ - $20^{\circ}\text{C}$ , depending on the load and ambient temperature. This model is designed to provide a reliable and inexpensive alternative to tap water.

The pump in the standard version KTR6\*\*\* may require priming, simply achieved by switching the unit on and off repeatedly until no bubbles are seen in the tank.

#### ***KTC models only***

Connect the mains cable and switch the unit on, and the temperature display will illuminate. KTC chillers have been configured to provide temperature stability to  $\pm 0.2^{\circ}\text{C}$ , and the actual temperature achieved will be in the range  $12^{\circ}\text{C}$ - $20^{\circ}\text{C}$ , depending on the load and ambient temperature. This model is designed to provide a reliable and inexpensive alternative to tap water.


The KTC includes digital coolant temperature display and high/low temperature and low fluid level alarms. The single neon and  icon provide visual alert to the alarm conditions:

High temperature alarm:	Preset at $15^{\circ}\text{C}$ – neon only
	Preset at $25^{\circ}\text{C}$ – neon, buzzer* and HI warning display
Low temperature alarm:	Preset at $8^{\circ}\text{C}$ – buzzer* and LO warning display
Low fluid alarm:	Neon and buzzer* only

\* The buzzer can be muted by pressing the MUTE button on the controller.

No adjustments can be made to the factory-set cooling parameters.

***KTD models only***

Connect the mains cable and switch the unit on, and after a short self-test, the temperature controller will show coolant temperature. The KTD chiller is fitted with a high performance 3 term PID controller, which is capable of controlling temperature to within 0.1°C of set point. The single neon, alert icon  and buzzer provide visual and audible alarm to both high *and* low temperature (triggered if the temperature deviates more than 10°C either side of the set point), and to low fluid level.

***Adjusting the set point (KTD only)***

There are three buttons on the controller, used to adjust the setpoint. Whilst depressing button **\***, press button **▼** or **▲** to decrease or increase the setpoint respectively.

If the set point is moved more than 10°C, the alarm may be triggered and the temperature will then have to stabilise at the new set point before the alarm stops.. It is not possible to set the temperature outside the preset values of -4°C and +35°C.

***CAL controller error messages (KTD only)***

Message displayed	Cause and correction
<b>InPt – FAiL</b>	Sensor has failed. Order replacement part number EA038
<b>Data – FAiL</b>	Controller problem. Switch off, then on. If problem is persistent, order replacement part EA055
- AL - (At start up)	Ambient temperature outside of permitted range, 5°C - 40°C
- AL - (After changing setpoint)	Restart the controller to reset the alarm
- AL - (During normal operation)	Fault on system. Refer to Troubleshooting section

## Fluid flow and pressure

KT chillers fitted with a 2 or 3 litre per minute pump are capable of producing up to 150 psi, because of the high pressure volumetric pump. These units are normally supplied factory set to run at an operating pressure of 35 psi, which is suitable for most applications. The pressure setting is controlled by an internal bypass valve, which will open above the preset level to protect your application from higher pressures.

It is possible for customers to change the operating pressure of all K series chillers, except KT chillers fitted with a 6 litre/minute pump<sup>1</sup>. For details of this procedure, refer to the technician section.

## 4.0 Maintenance requirements, Operator








**Caution:** Failure to carry out service at the specified intervals may permanently damage your equipment. For maintenance and service requirements for technicians, and for troubleshooting, refer to the technician section.

Exterior cleaning: Wipe up any spillages using a damp cloth only. Do not use detergents.

Interval	Actions
Weekly	Check fluid level Check external connections for leaks
Annually	Change the fluid

<sup>1</sup> The 6 litre/minute pump is specially designed for low pressure applications, and the flow rate and pressure settings cannot be changed on these units.

## 5.0 Technician section

-  **Warning:** Opening the refrigeration system may expose the operative to toxic and corrosive compounds (HF). Take protective measures including suitable eye protection.
-  **Warning:** Gases may exceed 300 psi (20 bar) during operation.
-  **Warning:** All refrigerants do not support combustion and are asphyxiating gases.
-  **Warning:** After switching off, the condenser cooling fan blades continue to rotate. Do not attempt servicing whilst the blades are rotating.
-  **Warning:** All chillers contain water and electricity in close proximity. Always ensure the unit is isolated before service. All K series chillers are protected from over current by the master circuit breaker. **Never bypass this component.**

### 5.1 Fluid flow and pressure adjustment

It is possible to change the operating pressure of all K series chillers, except KT chillers fitted with a 6 litre/minute pump<sup>2</sup>, as follows:

1. Remove the cover from the chiller, giving access to the top compartment.
2. With the chiller running, release the locking nut on the pressure relief valve.
3. Turn the valve knob anticlockwise to reduce the flow/pressure, clockwise to increase the flow/pressure.

<sup>2</sup> The 6 litre/minute pump is specially designed for low pressure applications, and the flow rate and pressure settings cannot be changed on these units.



**Caution:**

Changing the flow/pressure with the pressure relief valve will also change the preset pressure safety setpoint. This will move to a lower pressure than the factory setting when decreasing the flow/pressure, and to a higher pressure when increasing the flow/pressure.



**Caution:**

When the flow/pressure is manually increased by the pressure relief valve, the safety provided by the valve will be effected at higher pressures than standard. For this reason, please ensure that it is safe for your application to operate at pressures in excess of 35 psi. A blockage in your application could result in the pressure exceeding the raised safety pressure.

We recommend that *pressures exceeding 60psi must never be used.*

## 5.2 Maintenance and service requirements



**Caution:** Failure to carry out service at the specified intervals may permanently damage your equipment.

Interval	Actions
Weekly	Check fluid level (unless checked by Operator) Check external connections for leaks (unless checked by Operator)
Monthly	Check the condenser (air intake) is free from obstructions or accumulations of debris. Cleaning may be achieved with a domestic vacuum cleaner with brush attachment.*
Annually	Change the fluid (unless changed by Operator) Check for fluid leaks throughout the whole system. Check the condenser for fouling.



\* **Caution:** Never blow the condenser out with compressed air.

### 5.3 Troubleshooting

Symptom	Causes
Compressor not running, but fan running	<p>Is the controller displaying an alarm?</p> <p>If there is no obvious cause, check...</p> <ul style="list-style-type: none"> <li>The condenser is clean</li> <li>Ambient temperature not above 30°C</li> </ul> <p>The likely cause is the compressor's internal protection has been activated and should restart in five minutes.</p>
Noisy operation / High fluid pressure And/or low flow	<p>Check:</p> <ul style="list-style-type: none"> <li>No restrictions in the pipe work</li> <li>Pressure set too low (factory set pressure altered?)</li> </ul> <p>Clean system with weak detergent solution, rinse thoroughly to remove all detergent. Use Hexid fluid as coolant.</p>
Fluid lines becoming fouled brown or green	<p>Algae contamination.</p> <p>Clean system with weak detergent solution, rinse thoroughly to remove all detergent. Replace fluid lines with black lines, if not already fitted, to inhibit algae growth. Use Hexid fluid as coolant.</p>
Fluid seen leaking from system	<p>Under high humidity conditions, fluid may appear to be leaking from the system. This is usually just condensation, but do check for fluid leaks.</p>
Poor cooling	<p>Continued failure to cool may indicate high ambient temperature or excessive load applied to the unit. Check these first</p> <p>Otherwise, may be caused by blocked condenser.</p> <p>Clean with soft brush or vacuum cleaner with brush attachment</p>

---

## 6.0 Warranty terms and conditions

---

- i. ATC provides a comprehensive return to base **2 year parts, 1 year labour warranty** from delivery as standard on all new K series chillers, provided that they have been installed and operated in accordance with this manual.
- ii. At the discretion of ATC, goods may be serviced on site or a service loan unit may be supplied. Warranty cover excludes the cost of travel by engineers and loan unit rental charges.
- iii. During the first year of the warranty period, freight costs for shipping to ATC are for the customer's account. Freight costs for shipping from ATC are for ATC's account.
- iv. During the second year of the warranty, freight costs to and from ATC are for the customer's account.

### ***Registration***

The warranty registration card must be completed and returned to ATC.

This does not affect your statutory rights.

---

## 6.1 Return of goods procedure

---

If the unit is damaged during transit, or subsequently develops a fault requiring its return to ATC, the following procedure must be followed.

1. Call the ATC service point
  - You will be issued with a Return Materials Authorisation number ('Q number') and a Return Machine Declaration (RMD) form by fax. A copy of the RMD form is on the last page of this manual.
2. Return the completed RMD form to ATC by fax, together with your purchase order number, prior to shipment of the chiller.
3. Pack the returning item securely, enclosing a copy of the completed RMD form, and ensure that the packaging is clearly labelled with the Q number. Neither ATC nor your shipper will be liable for any damage incurred in transit.
4. Upon receipt of the completed RMD form, an engineer will be allocated or a service loan unit\* will be despatched if available.

\* Please note that ATC will raise an invoice as part of the service loan procedure, and you will receive a credit against this upon the safe return of the loan unit.

Address for return units:

Applied Thermal Control Ltd.  
Goods Inward  
Unit 14, The Courtyard  
Whitwick Business Park  
Stenson Road  
Whitwick  
Leicestershire, LE67 4JP  
UK

Tel: +44 (0) 1530 839998  
Fax: +44 (0) 1530 813786



---

## 6.2 Specifications

---

### ***Environmental***

- For indoor use only
- Altitude: up to 2000 metres
- Ambient temperature range: 4°C - 40°C
- Maximum relative humidity: 80% for ambient temperatures up to 31°C, decreasing linearly to 50% relative humidity at 40°C ambient temperature.
- Mains supply voltage not to exceed  $\pm 10\%$  of the nominal voltage.
- Installation Category II
- Pollution Degree 2

### ***KTR***

- Cooling capacity: 480 Watts at 22°C
- Dimensions, height x width x depth: 515 x 315 x 315mm (20 x 12.4 x 12.4 inches)
- Weight: 30kg (66lbs)
- Cooling temperature range: 4°C - 30°C
- Pumps available
  - High pressure volumetric type: 2litre/minute or 3litre/minute
  - Low pressure centrifugal type: 6 litre/minute
- Fluid connections: ¼" BSP x 10mm (3/8") Nickel plated brass hose tail adaptors. Custom connections available.
- Temperature stability:  $\pm 0.2^\circ\text{C}$ , with stable load, dependent on stable ambient temperature
- Power requirements: 3 Amps 230V 50/60Hz, 7 Amps 115V 60Hz
- Warranty: 2 years parts, 1 year labour.

### ***KTC***

- Cooling capacity: 480 Watts at 22°C
- Dimensions, height x width x depth: 515 x 315 x 315mm (20 x 12.4 x 12.4 inches)
- Weight: 30kg (66lbs)
- Cooling temperature range: 4°C - 30°C
- Pumps available
  - High pressure volumetric type: 2litre/minute or 3litre/minute
  - Low pressure centrifugal type: 6 litre/minute
- LED temperature display resolution: 1°C standard, 0.1°C option
- Fluid connections: ¼" BSP x 10mm (3/8") Nickel plated brass hose tail adaptors. Custom connections available.
- Temperature stability:  $\pm 0.2^\circ\text{C}$  with stable load, dependent on stable ambient temperature
- Power requirements: 3 Amps 230V 50/60Hz, 7 Amps 115V 60Hz
- Warranty: 2 years parts, 1 year labour.

---

**KTD**

- Cooling capacity: 480 Watts at 22°C
  - Dimensions, height x width x depth: 515 x 315 x 315mm (20 x 12.4 x 12.4 inches)
  - Weight: 30kg (66lbs)
  - Cooling temperature range: 4°C - 30°C
  - Pumps available
    - High pressure volumetric type: 2litre/minute or 3litre/minute
    - Low pressure centrifugal type: 6 litre/minute
  - LED temperature display resolution: 1°C standard, 0.1°C option
  - Fluid connections: ¼” BSP x 10mm (3/8”) Nickel plated brass hose tail adaptors. Custom connections available.
  - Temperature stability: ±0.1°C
  - Power requirements: 3 Amps 230V 50/60Hz, 7 Amps 115V 60Hz
  - Warranty: 2 years parts, 1 year labour.
-

## EC Declaration of Conformity

Applied Thermal Control Ltd.

Units 10 & 14 The Courtyard  
Whitwick Business Park  
Stenson Road  
Whitwick  
Leicestershire  
LE67 4JP


### **K series chiller range (all standard configurations)**

Serial Number: .....


The equipment meets the requirements of EEC Directive 73/23/EEC  
as amended by 93/68/EEC

Meets the directive on Electromagnetic compatibility  
89-336-EEC Specifications EN50081-1 (1992) (Emissions)  
and EN50082-1 (1992) Immunity

Signed



Norman White  
Director



Gareth Hall  
General Manager



In case of repair requirement, please complete both parts of the form, and fax to ATC

**PART 1: RETURNED MATERIAL DECLARATION FORM**

Returns Number: **Q0** \_ - \_\_\_\_

Your Name and Address:

.....  
.....  
.....  
.....

Your purchase order number:

.....

Machine part number:

Machine serial number:

.....  
.....

Collection for return to ATC – please tick one:

ATC to arrange shipment

Customer to arrange shipment

Reason for return:

.....

If faulty, list symptoms:

.....

Address for delivery of machine  
(if different from 1, above):

.....  
.....  
.....  
.....

Please note that a minimum non-refundable inspection fee of £60 will be charged on all equipment returned for repair with the exception of equipment still under warranty.

**PART 2: HEALTH & SAFETY DECLARATION**

Machine part number:

.....

Machine serial number:

.....

I, ....., of ....., confirm that the above unit is free from chemical, biological or nuclear hazard and that the unit presents no physical hazard, including electrical.

Signed and dated:

.....